



Certificate of Compliance

Certificate:	80270139	Master Contract:	179619
Project:	80270139	Date Issued:	2026-06-22
Issued to:	Kimray Incorporated 52 North West 42nd St. Oklahoma City, Oklahoma 73118 United States	Issued by:	<i>Dustin Pearce</i> Dustin Pearce

Attention: Ky Longley

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



PRODUCTS

Class 2258 02 PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class 2258 82 PROCESS CONTROL EQUIPMENT - For Hazardous Locations - Certified to US Standards

Class I, Division 1 Groups B, C, D T5

Class I, Zone 1 AEx db IIB+H2 T5 Gb

Type 4X

Electronic Level Sensor, Model KELS*, rated 10-30 Vdc, 4-20 mA, Ambient Temperature -40°C to +85°C. The equipment has been separately tested against the requirements of CSA C22.2 No. 60529:16 and IEC 60529 and it meets IP66.

Where: * is additional alpha-numeric characters that do not affect safety certification.



Certificate: 80270139

Master Contract: 179619

Project: 80270139

Date Issued: 2026-06-22

Conditions of Acceptability:

1. This equipment may only be powered by a power supply unit with a limited energy electric circuit in accordance with CAN/CSA C22.2 No. 61010-1-12 and ANSI/UL 61010-1, or Class 2 as defined in the Canadian Electrical Code C22.1, Section 16-200 and/or National Electrical Code (NFPA 70), article 725.121.
2. Flameproof joints are not intended to be repaired.

APPLICABLE REQUIREMENTS

Standards Used	Description
CAN/CSA C22.2 No. 61010-1-12, UPD1:2015, UPD2:2016, AMD1:2018, UPD3:2023, UPD4:2024	Safety requirements for electrical equipment for measurement, control, and laboratory use — Part 1: General requirements - Third Edition
CSA C22.2 No. 94.2:20 - Third Edition	Enclosures for electrical equipment, environmental considerations
CSA C22.2 No. 30:20 - Fourth Ed - Including Update No. 1 - March 2023	Explosion-proof equipment
CSA C22.2 No. 60079-0:19 - Fourth Edition	Explosive atmospheres - Part 0: Equipment - General requirements
CSA C22.2 No. 60079-1:16 - Third Edition	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
UL 61010-1:2012 - Third Edition - Revisions Through and Including November 15, 2024	Safety Requirements for Electrical Equipment For Measurement, Control, and Laboratory Use; Part 1: General Requirements
ANSI/UL 50E:2020 - Third Edition - Including revisions through April 30, 2024	Enclosures for Electrical Equipment, Environmental Considerations
ANSI/UL 1203-2024 - Sixth Edition	UL Standard for Safety ExplosionProof and Dust-IgnitionProof Electrical Equipment for Use in Hazardous (Classified) Locations - Including revisions through May 30, 2024
ANSI/UL 60079-0:2020 - Seventh Edition - Including revisions through July 19, 2024	Explosive Atmospheres – Part 0: Equipment – General Requirements
ANSI/UL 60079-1-2020 Seventh Edition	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures 'd'



Certificate: 80270139


Project: 80270139

Master Contract: 179619

Date Issued: 2026-06-22

Notes:

Products certified under Class(es) C225802, C225882 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 80270139

Master Contract: 179619

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80270139	2026-06-22	Original cCSAus certification of explosionproof protected Electronic Level Sensor KELS Series. Markings: XP Class I, Division 1 Groups BCD T5; Class I, Zone 1 AEx db IIB+H2 T5 Gb; -40 °C to +85°C; Type 4X, IP 66