



Certificate of Compliance

Certificate: 1578429

Master Contract: 179619

Project: 2566540

Date Issued: October 25, 2012

Issued to: **Kimray Incorporated**
Post Office Box 18255
Oklahoma City, OK 73154
USA
Attention: Ky Longley

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



David Taylor

Issued by: David Taylor

PRODUCTS

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div 1, Groups C and D; T6 @ Ta = 60°C.

Electro-Pneumatic Controller, Model #15 EPC, and #30 EPC series, Input rated 11-16 VDC, 225mA max, Model 100 EPC series, Input rated 11-16 VDC, 520mA max.

Where 15 EPC has a Oper. Pressure of 0-15 psi and a Current of 225mA.

30 EPC has a Oper. Pressure of 0-35 psi and a Current of 225mA.

100 EPC has a Oper. Pressure of 0-100 psi and a Current of 520mA

Note: Controller must be powered by an approved SELV source, in accordance with CSA C22.2 No. 1010.1, Annex H.

Notes:



Certificate: 1578429

Master Contract: 179619

Project: 2566540

Date Issued: October 25, 2012

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. (Protective Grounding)	0.4-04	- Bonding and Grounding of Electrical Equipment
CSA Std C22.2 No. Hazardous Locations	30-M1986	- Explosion-Proof Enclosures for Use in Class I
CAN/CSA-C22.2 No.	94-M91	- Special Purpose Enclosures
CAN/CSA-C22.2 No. Measurement, Control, and Laboratory Use	1010.1-92 (R1999)	- Safety Requirements for Electrical Equipment for
CAN/CSA-C22.2 No. Measurement, Control, and Laboratory Use	1010.1B-1997	- Safety Requirements for Electrical Equipment for (including Amendments 1 & 2)
TIL No.	I-29B	- Process Control Equipment in extended environments
UL Std No. 50 -	1995 (Ed. 11)	- Enclosures for Electrical Equipment
UL Std No. 61010-1 Measurement, Control, and Laboratory Use; Part 1: General Requirements	(Ed 2)	- UL Standard for Safety Electrical Equipment For
UL Std No. 1203 Equipment for Use in Hazardous (Classified) Locations	(Ed. 3)	- Explosion-Proof and Dust-Ignition-Proof Electrical